

PANEL HEATER SCHEDULE				
REF	LOCATION	MAKE/MODEL	HEATER SIZE	ROOM REQ.
R19	F4-LIVING/KITCHEN DINING ROOM	DIMPLEX ALTA WI-FI 40cm	1000W H-400 D-90 W-725	713W
R20	F4-BEDROOM 1	DIMPLEX ALTA WI-FI 40cm	750W H-400 D-90 W-625	314W
R21	F4 - HALLWAY	DIMPLEX ALTA WI-FI 40cm	750W H-400 D-90 W-625	442W
R22	F4 - BATHROOM	DIMPLEX TOWEL RAIL - TRM28W5	400W H-1475 W-500	920W

PANEL HEATER SCHEDULE - FLAT 5				
REF	LOCATION	MAKE/MODEL	HEATER SIZE	ROOM REQ.
R23	F5-KITCHEN	DIMPLEX ALTA WI-FI 40cm	500W H-400 D-90 W-525	418W
R24	F5-LIVING/DINING KITCHEN ROOM	DIMPLEX ALTA WI-FI 40cm	1000W H-400 D-90 W-725	673W
R25	F5 - BEDROOM 4	DIMPLEX ALTA WI-FI 40cm	750W H-400 D-90 W-625	276W
R26	F5 - BATHROOM	DIMPLEX TOWEL RAIL - TRM28W5	400W H-1475 W-500	906W
R27	F5 - BEDROOM 3	DIMPLEX ALTA WI-FI 40cm	750W H-400 D-90 W-625	306W
R28	F5 - EN-SUITE 1	DIMPLEX TOWEL RAIL - TRM28W5	400W H-1475 W-500	926W
R29	F5 - ENSUITE 2	DIMPLEX TOWEL RAIL - TRM28W5	400W H-1475 W-500	956W
R30	F5 - BEDROOM 2	DIMPLEX ALTA WI-FI 40cm	750W H-400 D-90 W-625	279W
R31	F5 - HALL	DIMPLEX ALTA WI-FI 40cm	500W H-400 D-90 W-525	322W
R32	F5 - EN-SUITE	DIMPLEX TOWEL RAIL - TRM28W5	400W H-1475 W-500	1031W
R33	F5 - BEDROOM 1	DIMPLEX ALTA WI-FI 40cm	750W H-400 D-90 W-625	399W



LEGEND



RADIATOR
TOWEL RAIL

© COPYRIGHT EDP:
THIS DRAWING REMAINS THE PROPERTY OF EDP ENVIRONMENTAL.
NOTE: DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS SHALL BE CHECKED ON SITE. ONLY FIGURED DIMENSIONS SHALL BE USED. IF IN DOUBT, ASK.
THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL RELEVANT DRAWINGS, DOCUMENTS AND INFORMATION PREPARED BY THE ARCHITECT, OTHER CONSULTANTS AND SPECIALISTS. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH EDP ENVIRONMENTAL MECHANICAL & ELECTRICAL SERVICES SPECIFICATION & TECHNICAL SCHEDULES

HEALTH & SAFETY
STANDARD CONSTRUCTION HAZARDS THAT A COMPETENT CONTRACTOR WOULD BE AWARE OF DURING NORMAL WORKING PRACTICES ARE NOT IDENTIFIED ON THIS DRAWING. RISKS THAT MAY NOT BE IMMEDIATELY APPARENT ARE LISTED BELOW.

NOTES

- ALL HEAT SOURCES SHALL BE INSTALLED, TESTED, AND COMMISSIONED IN ACCORDANCE MANUFACTURERS RECOMMENDATIONS.

P01	31.07.25	FIRST ISSUE
REV	DATE	REVISION DESCRIPTION
SCHEDULE OF REVISIONS		

Architects Model:
Structural Model:
Other Model:
Model Schedule Key: [Discipline] _ [Date Received] _ [Revision] _ [Specific Model Number]



HEAD OFFICE
EMBLEM HOUSE
PYNES HILL
EXETER, EX2 5BA
EXETER T: 01392 367 237
BRISTOL T: 01173 256 975
FAREHAM T: 01329 800 710
LONDON T: 02076 091 899
CHOBHAM T: 01276 300 280

CLIENT:
COUNCIL OF THE ISLES OF SCILLY

PROJECT:
PARK HOUSE, ISLES OF SCILLY
DRAWING TITLE:
HEATING AND VENTILATION

FIRST FLOOR
SERVICE TYPE:
MECHANICAL
DRAWING STATUS CODE:
REVIEW AND COMMENT

SCALE @ A1
1:50
INTERNAL PROJECT REF:
2606

DRAWING NUMBER:
2606-EDP-XX-01-DR-M-1004

PROJECT NUMBER - ORIGINATOR - ZONE - LEVEL - TYPE - ROLE - SEQUENTIAL NUMBER

Designed by: NO
Drawn by: NO
Checked by: SO
Revision: P01