

COUNCIL OF THE ISLES OF SCILLY

PLANNING APPLICATION REPRESENTATION (RECEIVED VIA COUNCIL'S WEBSITE)

Name:	Robert Charles Tune – Spanish Ledge Management Company
Address:	Unit 4, Leaton Forest Offices Leaton Knolls Shrewsbury SY4 3HX
Email:	Email address provided
Date Received:	20/02/2015
Application:	P/15/009/LBC – Town Hall, The Parade, St Mary's
Representation:	We understand that this application is taking into consideration the impact of 2 air conditioning units on the roof of a Grade II listed building. However, there is no technical specification of the units attached to the application. There is only a drawing regarding installation of what would appear to be internal units venting to the outside. If these units are to be mounted on the roof the instructions clearly state that they must be at least 50cm from any wall or obstacle. Therefore the siting of these units would not meet this criteria. Without any specification it is impossible to judge the noise impact affecting local residents and holidaymakers. Noise from motors venting to the outside would be considerably less than motors mounted on a roof pulling air up from inside. Surely internal wall/ceiling mounted heat handling units which can control room temperatures to an external vent would be a better solution? We would ask that either more information is provided or an alternative solution is considered before the planning committee considers an application.