

Council of the Isles of Scilly Planning Application

Ref: P/19/055/FUL

Consultation Response

Consultee: Sewerage**Date:** 20th September 2019**Ref:** P/19/055/FUL**Site:** Sibleys Fuel And Marine Storage, 28 - 29 Porthmellon Industrial Estate, Porth Mellon, St Mary's.**Proposal:** Change of use of part of Bay One into two bedroom staff accommodation..

You are being consulted on this application as you may wish to make comments before a decision is made. Should you wish to make any comments on this application, please complete the response form below and return to planning@scilly.gov.uk by 11th October 2019 or by post to the Planning Department, Town Hall, The Parade, Hugh Town, St Mary's, Isles of Scilly TR21 0LW.

I look forward to receiving your comments in due course. If I have not heard back from you by the 11th October 2019 then I will assume you have no comments to make.

Comments:

Frequent blockages and failures occur within the sewerage infrastructure network of the Industrial Estate which is considered to be nearing capacity.

Should the application be approved and connected it should, through a planning condition, demonstrate a reduction in discharge into the network by the use/installation of the latest up to date water saving devices to further reduce the impact on the sewerage network/service in the area.

Name: E. Williams/H. Richards**Date:** 04/10/19