

From: [Nottle Terry \(Fire\)](#)
To: [Walton Lisa](#)
Subject: P/19/064/FUL Scillonia Building Supplies, 21 Porthmellon Ind Estate
Date: 27 November 2019 08:44:14

Information Classification: CONTROLLED

Good Morning

Fire Service response on the above application.

Access for the Fire Service to meet the requirements of B5.

60 minutes fire resistance required between commercial and sleeping accommodation

Regards Terry

Terry Nottle EngTech MIFireE
Station Manager East Command

Cornwall Fire, Rescue and Community Safety Service
Neighbourhoods Directorate

Mob: 07973176270 Email: terry.nottle@fire.cornwall.gov.uk

Bodmin Fire Station Berrycombe Rd Bodmin PL31 2NS

www.cornwall.gov.uk/fire

Like us on Facebook
Follow us on Twitter

Working together to make Cornwall safer

Please let us know if you need any particular assistance from us, such as facilities to help with mobility, vision or hearing, or information in a different format.

Please consider the environment. Do you really need to print this email?