

Council of the Isles of Scilly Planning Application

Ref: P/21/108/HH

Consultation Response

Date: 23rd December 2021

Ref: P/21/108/HH

Site: Valhalla, Abbey Road, Tresco, Isles of Scilly

Proposal: Demolition of lean-to extension, construction of new single storey extension, installation of new dormer windows, construction of new swimming pool and other internal and external alterations. (Affecting setting of a listed building).

You are being consulted on this application as you may wish to make comments before a decision is made. Should you wish to make any comments on this application, please complete the response form below and return to planning@scilly.gov.uk by 21st January 2022 or by post to the Planning Department, Town Hall, The Parade, Hugh Town, St Mary's, Isles of Scilly TR21 0LW.

Link to application: <https://www.scilly.gov.uk/planning-application/planning-application-p21108hh>

I look forward to receiving your comments in due course. If I have not heard back from you by the 21st January 2022 then I will assume you have no comments to make.

Consultee Name:

[Comments here](#)

Access and Facilities for the Fire Service as detailed in B5 ADB Volume 1 will be required. For dwelling houses access for a pumping appliance should be provided to within 45m of all points inside the dwelling house.

It is important to remember that failure to do so may prevent the applicant from obtaining a completion certificate under the Building Regulations but more importantly, the lives of the occupiers will be put at risk.

Name: Darren Vincent (Business Fire Safety Officer Cornwall Fire & Rescue Service)

Date: 4th January 2022