

From: [Tanya Saker](#)
To: [Lisa Walton](#)
Cc: [Zero Waste Scilly](#); [Russell Thompson](#); [Eddie Williams](#)
Subject: RE: P/22/052/COU Treboeth, 5 Buzza Street, Hugh Town St Mary's
Date: 14 October 2022 11:53:22
Attachments: [image002.png](#)
[image003.png](#)
[image004.png](#)
[image005.png](#)
[image006.png](#)

Hi Lisa

Thanks for flagging this one.

I can confirm that Waste should be stored within the boundary of the property, and placed out on the highway on the day of collection.

I would advise that the plans should include the provision of secure commercial waste and recycling storage within the boundary of the property, taking into account both current and future waste and segregated recycling requirements laid out in the Government's Environment Act.

At the very least, the provision of waste and recycling storage should be sizeable enough to accommodate residual waste, segregated cardboard, plus food recycling (which is likely to be implemented in line with the Government's requirements to provide segregated food recycling), with scope to extend as increased segregation is required by Law.

This waste will be classified as Commercial waste and therefore will need to be collected by a commercial waste contractor.

Thanks

Tanya
