

Council of the Isles of Scilly Planning Application

Ref: P/23/042/HH
P/23/043/LBC

Re-Consultation Response

RECEIVED

By Lisa Walton at 5:30 pm, Nov 07, 2023

Date: 13/10/2023

Ref: P/23/042/HH & P/23/043/LBC

Site: St Eia, Hugh Street, St Mary's, Isles Of Scilly

Proposal: Proposed alterations and extension including new conservatory and garage, renovation of existing rear porch, alterations to existing layout, re-wiring, removal of existing coal store, greenhouse and part boundary wall (Listed Building) (Amended Plans)

You are being consulted on this application as you may wish to make comments before a decision is made. Should you wish to make any comments on this application, please complete the response form below and return to planning@scilly.gov.uk by **27th October 2023** or by post to the Planning Department, Town Hall, The Parade, Hugh Town, St Mary's, Isles of Scilly TR21 0LW.

Link to application: <https://www.scilly.gov.uk/planning-application/planning-application-p23042hh>
<https://scilly.gov.uk/planning-application/planning-application-p23043lbc>

I look forward to receiving your comments in due course. If I have not heard back from you by the **27th October 2023** then I will assume you have no comments to make.

Consultee Name: Cornwall Fire & Rescue Service

(Comments)

Access for fire appliances within the site will be considered satisfactory providing it complies with Part B5 of Approved Document B, Vehicle Access.

Adequate water supplies for firefighting purposes will be achieved by complying with the requirements of Part B5 of Approved Document B.

Council of the Isles of Scilly

Planning Application

Ref: P/23/042/HH
P/23/043/LBC

The fire authority would remind the applicant a Building Regulations consultation with the local authority, or an Approved Inspector will be required for this development should planning permission be granted.

Name: Graham Hughes

Date: 06 November 2023