

# Council of the Isles of Scilly Planning Application

Ref: P/23/063/HH

## Consultation Response

**Date:** 22/08/2023  
**Ref:** P/23/063/HH  
**Site:** Wingletang, The Parade, St Mary's, Isles of Scilly  
**Proposal:** Internal refurbishment with minor alterations, provision of new staircase and alterations to elevations to rear of property (Listed Building).

You are being consulted on this application as you may wish to make comments before a decision is made. Should you wish to make any comments on this application, please complete the response form below and return to [planning@scilly.gov.uk](mailto:planning@scilly.gov.uk) by **13<sup>th</sup> September 2023** or by post to the Planning Department, Town Hall, The Parade, Hugh Town, St Mary's, Isles of Scilly TR21 0LW.

Link to application: <https://www.scilly.gov.uk/planning-application/planning-application-p23063hh>

I look forward to receiving your comments in due course. If I have not heard back from you by the **13<sup>th</sup> September 2023** then I will assume you have no comments to make.

**Consultee Name:**

---

Access for fire appliances within the site will be considered satisfactory providing it complies with Part B5 of Approved Document B, Vehicle Access.

Adequate water supplies for firefighting purposes will be achieved by complying with the requirements of Part B5 of Approved Document B.

The fire authority would remind the applicant a Building Regulations consultation with the local authority, or an Approved Inspector and the Fire Authority will be required for this development should planning permission be granted.

---

# Council of the Isles of Scilly Planning Application

Ref: P/23/063/HH

**Name:**

**Date:**