

# Council of the Isles of Scilly Planning Application

Ref: P/24/008/COU

## Consultation Response

**Date:** 13.02.2024  
**Ref:** P/24/008/COU  
**Site:** Sunnycreek, Garrison Lane, Hugh Town, St Mary's, Isles of Scilly, TR21 0JD  
**Proposal:** Change of use of garage/kitchen to a hot food takeaway outlet.

You are being consulted on this application as you may wish to make comments before a decision is made. Should you wish to make any comments on this application, please complete the response form below and return to [planning@scilly.gov.uk](mailto:planning@scilly.gov.uk) by the **5<sup>th</sup> March 2024**.

Link to application: <https://scilly.gov.uk/planning-application/planning-application-p24008cou>

I look forward to receiving your comments in due course. If I have not heard back from you by the **5<sup>th</sup> March 2024** then I will assume you have no comments to make.

**Consultee Name: Michael Coates, Head of Regulatory Services**

---

Best practicable means should be incorporated into the design of the new commercial kitchen extract ventilation system, which is intended to be installed within the hot food takeaway outlet at Sunnycreek, St Marys; to mitigate any potential noise or smell nuisance.

The rating level (LAeq, T) from the fixed plant and machinery, should not exceed the background noise level (LA90,T) at any time when measured at the nearest noise sensitive source.

All ductwork serving the new commercial kitchen extract ventilation system should be fitted with anti-vibration mounts to minimise vibration at adjacent sensitive premises.

---

**Name: Michael Coates, Head of Regulatory Services**

**Date: 4<sup>th</sup> March 2024**