

Council of the Isles of Scilly Planning Application

Ref: P/24/018/COU

RECEIVED

By Liv Rickman at 11:23 am, Apr 17, 2024

Consultation Response

Date: 25.03.2024

Ref: P/24/018/COU

Site: Porthloo House, Porthloo, St Mary's, Isles of Scilly

Proposal: Change of use of redundant gallery/studio space to domestic area.

You are being consulted on this application as you may wish to make comments before a decision is made. Should you wish to make any comments on this application, please complete the response form below and return to planning@scilly.gov.uk by the **15th April 2024**.

Link to application: <https://scilly.gov.uk/planning-application/planning-application-p24018cou>

I look forward to receiving your comments in due course. If I have not heard back from you by the **15th April 2024** then I will assume you have no comments to make.

Consultee Name: Cornwall Fire & Rescue Service

Access for fire appliances within the site will be considered satisfactory providing it complies with Part B5 of Approved Document B, Vehicle Access.

Adequate water supplies for firefighting purposes will be achieved by complying with the requirements of Part B5 of Approved Document B.

Should planning permission be granted, the fire authority would remind the applicant The Regulatory Reform (Fire Safety) Order 2005 applies, and the responsible person will be required to carry out a fire risk assessment to identify the risks and take reasonable measures to ensure people are safe from fire.

Name: Graham Hughes

Date: 15 April 2024