

Council of the Isles of Scilly Planning Application

Ref: P/24/019/COU

Consultation Response

Date: 03.04.2024
Ref: P/24/019/COU
Site: Circus Field, Church Road, Hugh Town, St Mary's, Isles of Scilly
Proposal: Temporary use of field for construction site welfare facilities and the storage of materials in conjunction with planning ref P/24/006/FUL

You are being consulted on this application as you may wish to make comments before a decision is made. Should you wish to make any comments on this application, please complete the response form below and return to planning@scilly.gov.uk by the **24th April 2024**.

Link to application: <https://scilly.gov.uk/planning-application/planning-application-p24019cou>

I look forward to receiving your comments in due course. If I have not heard back from you by the **24th April 2024** then I will assume you have no comments to make.

Consultee Name: Michael Coates, Head of Regulatory Services (Environmental Health)

The rating level (LAeq, T) from any generator installed and run on site should not exceed the background noise level (LA90,T) at any time when measured at the nearest noise sensitive source.

Ensure arrangements are in place to collect any wastewater/sewerage from any sealed waste collection systems serving the welfare facilities on site to prevent any potential odour nuisance at the nearest sensitive source and to ensure safe disposal of such waste.

Name: Michael Coates

Date: 24th April 2024