

Council of the Isles of Scilly Planning Application

Ref: P/24/049/ROV

Consultation Response

Date: 09.07.2024
Ref: P/24/049/ROV
Site: SWW Temporary Construction Compound, Parting Carn Lane, Parting Carn, St Mary's, Isles of Scilly
Proposal: Application to vary condition C2 (Approved Plans) of planning permission [P/23/086/COU](#) (Temporary use of land as a construction compound with associated welfare facilities to support South West Water upgrade to waste and water infrastructure across the Isles of Scilly for up to four years) to increase number of sleeping units

You are being consulted on this application as you may wish to make comments before a decision is made. Should you wish to make any comments on this application, please complete the response form below and return to planning@scilly.gov.uk by the **30th July 2024**.

Link to application: <https://www.scilly.gov.uk/planning-application/planning-application-p24049rov>

I look forward to receiving your comments in due course. If I have not heard back from you by the **30th July 2024** then I will assume you have no comments to make.

Consultee Name: Cornwall Fire and Rescue Service

(Comments)

Access for fire appliances within the site will be considered satisfactory providing it complies with Part B5 of Approved Document B, Vehicle Access.

As the proposal seeks to provide sleeping accommodation for longer than 28 days the fire authority would advise the applicant a Building Regulations consultation with the local authority, or an Approved Inspector will be required should planning permission be granted.

Council of the Isles of Scilly Planning Application

Ref: P/24/049/ROV

The Fire Authority should also be consulted as part of the Building Regulations application to ensure compliance with The Regulatory Reform [Fire Safety] Order 2005.

Name: Graham Hughes

Date: 12 July 2024