

**RECEIVED**

By Liv Rickman at 5:31 pm, Jan 09, 2025

# Council of the Isles of Scilly Planning Application

Ref: P/24/088/HH

## Consultation Response

**Date:** 29.11.2024  
**Ref:** P/24/088/HH  
**Site:** 2 Silver Street, Hugh Town, St Mary's, Isles of Scilly  
**Proposal:** Replacement of rear extension window with new door.

You are being consulted on this application as you may wish to make comments before a decision is made. Should you wish to make any comments on this application, please complete the response form below and return to [planning@scilly.gov.uk](mailto:planning@scilly.gov.uk) by the **20<sup>th</sup> December 2024**.

Link to application: <https://scilly.gov.uk/planning-application/planning-application-p24088hh>

I look forward to receiving your comments in due course. If I have not heard back from you by the **20<sup>th</sup> December 2024** then I will assume you have no comments to make.

**Consultee Name: Council of the Isles of Scilly, Lead Local Flood Authority.**

---

The proposal is to remove the existing window on the east elevation of the property and replace this with a fire door; remove the kitchenette and replace with a sitting room.

The Flood Risk Assessment (FRA) contained within the planning application states that the site is located within Flood Zone 3 – High Flood Risk and all three access doors will have removable flood gates.

It is agreed that 2 Silver Street is located within Flood Zone 3 – High Flood Risk Zone.

Since the application refers to a replacing a window with a door, this would be described as Minor development – “alterations to an existing building which do not increase the size of the building”.

For all development covered by the standing advice for Minor Development, a FRA should include:

---

# Council of the Isles of Scilly Planning Application

Ref: P/24/088/HH

- your site address
- a description of your development
- the estimated flood level for your development, taking into account the impacts of climate change over its lifetime
- details of the finished floor levels
- details of your flood resistance and resilience plans
- any supporting plans and drawings
- any other information the relevant standing advice tells you to include

The estimated flood level is the depth of flooding anticipated on your development site.

The FRA should determine the risk of flooding from all sources and if the major risk of flooding to this site is tidal, the 1 in 200 annual probability event plus an allowance for climate change should be used to describe the likely flood depths to the site. All levels (Proposed Finished Floor Levels and expected flood levels) should be to Ordnance Datum.

The current Flood Risk Assessment identifies the Flood Risk Zone and that a flood gate will be used on all three access doors, but is lacking in detail when considering the Standing Advice above. Please can the FRA be updated to assess what the likely flood depths will be at the property. The depth of water will influence the specification of the flood gate.

Further detail should be provided in relation to the type of flood gate. The information provided in the FRA states flood gates, but should this be a flood barrier? The details should provide information on the type of flood defence product considering the depth of water, door recess, threshold, wall material and where the gate will be stored. What will be the maintenance for this barrier, who will do the annual maintenance and who will be responsible for erecting the barrier? Would this be the homeowner, or tourists if the property is being let? Could a visitor with no training be reasonably expected to erect and manage a flood barrier?

**Name: Rebecca Williams**

**Date: 07 01 2024**