

Council of the Isles of Scilly Planning Application

Ref: P/25/012/HH

Consultation Response

Date: 25.02.2025

Ref: P/25/012/HH

Site: 7 Lower Strand, Hugh Town, St Mary's, Isles of Scilly

Proposal: Ground floor and first floor rear extension and addition of historical bay window to the front elevation.

You are being consulted on this application as you may wish to make comments before a decision is made. Should you wish to make any comments on this application, please complete the response form below and return to planning@scilly.gov.uk by the **18th March 2025**.

Link to application: <https://scilly.gov.uk/planning-application/planning-application-p25012hh>

I look forward to receiving your comments in due course. If I have not heard back from you by the **18th March 2025** then I will assume you have no comments to make.

Consultee Name: Cornwall Fire and Rescue Service

(Comments)

Access for fire appliances within the site will be considered satisfactory providing it complies with Part B5 of Approved Document B, Vehicle Access.

Should the premises proposed use be for short term holiday letting or similar the Fire Authority must be consulted as part of the Building Regulation process.

Name: Graham Hughes

Date: 27 February 2025