

[REDACTED]

To:

Subject:

Date:

[REDACTED]

[REDACTED]

[Planning \(Isles of Scilly\)](#)

RE: P/25/048/LBC | The Chaplaincy, St Mary's

01 July 2025 08:47:54

[REDACTED]

Information Classification: CONTROLLED

[REDACTED]

The updated joinery details show the use of slim profile double glazing, which responds positively to our earlier advice and is welcomed. We recommend it is clarified that the glazing is to be putty fixed.

Regarding the replastering, we advise that some further investigation to understand the level of dampness in the wall and its construction would be beneficial. Whilst we understand the applicants desire to limit any disruption within the building but removal of a trial area of existing plaster and assessment of the condition of the wall beneath would assist in agreeing the best course of action.

Alternatively, a condition could be imposed to agree the specification for the replastering following opening up works.

[REDACTED]

[REDACTED]

Victoria Robinson BSc(Hons) PGDip | Senior Development Officer (Historic Environment Planning)

Cornwall Council | Planning and Housing

[REDACTED]

[REDACTED]

Email is the best way to contact me. I am part time and my normal working days are Tues-Fri